

Certificate of Compliance

Certificate Number **20090528-E314374**
Report Reference **E314374, 2007 December 03**
Issue Date **2009 May 28**

Page 1 of 2



Issued to:

DATAKOM ELEKTRONIK MUHENDISLIK LTD STI

YUKARI DUDULLU KUTUP SOKAK 28
UMRANIYE TURKEY

*This is to certify that
representative samples of*

AUXILIARY DEVICES

DKG series, models: DKG105, DKG107, DKG117, DKG151, DKG152, DKG153, DKG154, DKG155, DKG171, DKG207, DKG217, DKG227, DKG307, DKG317, DKG327, DKG507, DKG507J, DKG517, DKG517J, DKG527, DKG537, DKG547, DKG557, DKG703, DKG705 and DKG707

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*


Standard(s) for Safety:

UL508 - Industrial Control Equipment
C22.2 No.14-05 - Industrial Control Equipment

Additional Information:

See Addendum for Ratings

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:
Jose Carrascosa, Team Leader Engineer
Underwriters Laboratories Inc.

Reviewed by:
Matteo Redaelli, Group Leader Engineer
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number **20090528-E314374**
Report Reference **E314374, 2007 December 03**
Issue Date **2009 May 28**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Power supply input:	12-30Vdc Limited Voltage/Current
Current sensing inputs:	5A
Phase inputs:	300Vac
Standard Digital inputs:	30Vdc Limited Voltage/Current
Generator Contactor Output (models DKG207, DKG217, DKG307, DKG317, DKG507, DKG517):	120Vac, 10A General Purpose
Generator Contactor Output (models DKG105, DKG107, DKG171, DKG327, DKG507J, DKG517J, DKG527, DKG537, DKG547, DKG557, DKG703, DKG705):	120Vac, 16A General Purpose
Control Outputs (model DKG155):	28Vdc, 16A
Control Outputs (models DKG105, DKG107, DKG117, DKG151, DKG152, DKG171, DKG207, DKG217, DKG227, DKG307, DKG317, DKG327, DKG507, DKG507J, DKG517 DKG517J, DKG527, DKG537, DKG705):	28Vdc, 10A
Control Outputs (models DKG153, DKG154, DKG547, DKG557, DKG703, DKG707):	28Vdc, 1A

Device suitable for a surrounding air temperature of 40°C.

Issued by:
Jose Carrascosa, Team Leader Engineer
Underwriters Laboratories Inc.

Reviewed by:
Matteo Redaelli, Group Leader Engineer
Underwriters Laboratories Inc.